

Irrigation

Quantity	Symbol	Description	Part Number	Pressure	Flow	Radius
1		Hunter 10A-240-INST-04	10A	30	1.3	10
1		Hunter 10A-270-INST-04	10A	30	1.46	10
4		Hunter 10F-INST-04	10F	30	1.95	10
67		Hunter 10H-INST-04	10H	30	0.97	10
35		Hunter 10Q-INST-04	10Q	30	0.49	10
1		Hunter 15A-120-INST-04	15A	30	1.24	15
21		Hunter 15A-180-INST-04	15A	30	1.86	15
5		Hunter 15A-360-INST-04	15A	30	3.71	15
2		Hunter 15A-45-INST-04	15A	30	0.46	15
4		Hunter 15A-90-INST-04	15A	30	0.93	15
14		Hunter 7H-INST-04	7H	30	0.48	7
8		Hunter 7Q-INST-04	7Q	30	0.24	7
1		Hunter RCS-01S-INST-04	RCS-01S	30	0.65	15
1		Hunter SI-520-INST-04	SI-520	30	1.2	30
2		Hunter I-20-.50-SR I-20-ADJ	.50-SR	50	0.5	18
1		Hunter I-20-1.0-I-20-ADJ	1.0	50	1.2	31
4		Hunter I-20-1.0-SR I-20-ADJ	1.0-SR	50	1	18
10		Hunter I-20-1.5-I-20-ADJ	1.5	50	1.6	34
2		Hunter I-20-1.5-SR I-20-ADJ	1.5-SR	50	1.5	35
1		Hunter I-20-2.0-I-20-ADJ	2.0	50	2.1	46
5		Hunter I-20-3.0-I-20-ADJ	3.0	50	2.7	46
1		Hunter I-20-4.0-I-20-ADJ	4.0	50	4.2	43
49		Hunter PCN-00	PCN-00	25	0.5	0
2						
2		Wilkins 975XL - 1"	975XL - 1"			
32		Hunter SRV-100G	SRV-100G			
987.25		Schedule 40 1 1/4"				
787.21		Schedule 40 1"				
2652.44		Schedule 40 3/4"				

PLAN0 DE SITUACION - ALTERNA #2

SCALE: 1:200

aybar-imbert, rivera, cardona & assoc.
architects * engineers * interior planners
121 O'NEILL ST., HATO REY, P.R., 00918 (787) 753-7614, FAX 759-9631
P. O. BOX 40500, MINILLAS STATION, SANTURCE, PUERTO RICO, 00940
ARCHITECTS

ISSUE DATE
AS NOTED

NO.	DATE	REVISIONS

BEAUCHAMP - PUNTA CANA

THIS DRAWING DEPICTS THE DESIGN CONCEPTS AND IDEAS OF AYBAR - IMBERT, RIVERA, CARDONA & ASSOCIATES ARCHITECTS AND ARCHITECTURAL DESIGN AND ARRANGEMENT OF THE SERVICES SHOWN THEREON ARE AND SHALL REMAIN THE PROPERTY OF THE OFFICE. THEY ARE NOT TO BE USED OR REPRODUCED OR DISTRIBUTED IN ANY FORM WITHOUT PRIOR WRITING IS GRANTED.

SI-2